

2007 ANNUAL DRINKING WATER QUALITY REPORT

PWSID#: 4140084 NAME: Millheim Borough

Este informe contiene información muy importante sobre su agua de beber. Tradúzcalo ó hable con alguien que lo entienda bien. (This report contains very important information about your drinking water. Translate it, or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Roy Rupert @814-349-5350

We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held at the Millheim Borough Building on the second Tuesday of each month @7:00 PM

SOURCES OF WATER:

Phillips Creek Reservoir and Elk Creek during times of low flow

A Source Water Assessment of our source(s) was completed in 2002 by the PA Department of Environmental Protection (PADEP). The Assessment has found that our source(s) is/are potentially most susceptible to road deicing materials, accidental spills along roads. Overall, our source(s) has: little. Risk of significant contamination. Summary reports of the Assessment are available by writing to Millheim Borough P.O.Box 421 225 East Main St. Millheim, PA 16854 and will be available on the PADEP website at www.dep.state.pa.us (Keyword: "DEP source water"). Complete reports were distributed to municipalities, water supplier, local planning agencies and PADEP offices. Copies of the complete report are available for review at the PADEP Williamsport Office, Records Management Unit at 570-327-3636.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2007. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS AND ABBREVIATIONS:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Mrem/year = millirems per year (a measure of radiation absorbed by the body)

pd/L = picocuries per liter (a measure of radioactivity)

ppm = parts per million, or milligrams per liter (mg/L)

ppb = parts per billion, or micrograms per liter, (M9/L)

DETECTED SAMPLE RESULTS:

Chemical Contaminant	MCL InCCR Units	MCLG	Highest Level Detected	Range of Detections	Units	Violation Y/N	Sources of Contamination	
Chlorine	MRDL = 4	MRDL = 4	1.7	0.30-1.7	mg/L	N	Water additive used to control microbes	
Trihalomethanes (TTHM)	80	80	0.0382	0.0382	ppb	N	By-product of drinking water chlorination	
Haloacetic acids five (HAAS)	60	60	0.0813	.0489 - .0813	ppb	N	By-product of drinking water chlorination	
Total Organic Carbon	TT	TT	0.68	.58 - .68	mg/L	N	Total organic carbon (TOC) has no health effects	
Contaminant	Action Level (AL)	MCLG	90 th Percentile Value	Units	# of Sites Above AL of Total Sites	Violation Of TT Y/N	Sources of Contamination	
Lead	15	0	0.000	ppb	10	N	Corrosion of household plumbing	
Copper	1.3	1.3	0.2300	ppm	10	N	Corrosion of household plumbing	
Contaminant	MCL			MCLG	Level Detected	Sample Date	Violation Of TT Y/N	Source of Contamination
Turbidity	TT=1 NTU for a single measurement			0	NTU	Cent.	N	Soil runoff
	TT= at least 95% of monthly samples <0.3 NTU				100%	Cont.	N	

OTHER VIOLATIONS:

During the fourth quarter of 2007 Arsenic and IOC samples were missed due to computer issues- Follow up samples were taken upon discovery of this mistake. All sample results were satisfactory.

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. PDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health .Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).